

VOC Content Test Certificate

Friday, 08th June 2018

Supplier: Soudal Pty Ltd Australia (1 Tollis Place, Seven Hills, NSW 2147).

Sample Description: MultiBond SMX35

Date Tested: January 2018 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Design & As Built V1.1 13.1.1 Green Star Interiors V1.1 12.1.1B	MultiBond SMX35
General purpose adhesives and sealants: 50 grams per Litre as VOC content per material	8 grams per Litre as VOC content per material
<i>We hereby certify MultiBond SMX35 is well below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i>	
<i>The above results may be considered of Multibond SMX35 product at different colours which are made from the same raw material specified by Soudal these include Concrete Grey, White, Black, Off White, Beige, Sandstone, and Dark Grey.</i>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Nick Joy
BSc (Hons)
Consultant

CV180607