

VOC Content Test Certificate

Thursday 9th May 2024

Supplier: SOUDAL Pty Ltd Australia (75 Owen Street, Glendenning, NSW, 2761, Australia)

Product name: MultiBond SMX50

Date Tested: May 2024 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:


Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B	MultiBond SMX50
General Purpose Adhesives and Sealants limit: 50 grams per litre	8 grams per litre as VOC content per material
<i>We hereby certify MultiBond SMX50 is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chemical Engineer)
Senior Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant

Issue Date: 9/05/2024

Expiry date: 9/05/2029

P24030144