

# VOC Content Test Certificate

Thursday 9<sup>th</sup> May 2024

Supplier: SOUDAL Pty Ltd Australia (75 Owen Street, Glendenning, NSW, 2761, Australia)

Product name: SMX-30 Plus Timber Flooring Adhesive

Date Tested: May 2024 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

## Test Data:


<b>Specification</b> <b>Green Building Council of Australia</b> <b>Green Star Design &amp; As Built V1.3-13.1.1B</b> <b>Green Star Interiors V1.3-12.1.1B</b>	<b>SMX-30 Plus Timber Flooring Adhesive</b>
<b>General Purpose Adhesives and Sealants limit:</b> <b>50 grams per litre</b>	<b>28 grams per litre as VOC content per material</b>
<i>We hereby certify SMX-30 Plus Timber Flooring Adhesive is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i>	



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Dr. Tuan Duong  
PhD, BE (Chemical Engineer)  
Senior Consultant



Travis Hale  
BSc (Biotechnology)  
Senior Consultant

Issue Date: 9/05/2024

Expiry date: 9/05/2029

P24030144